

Ljudtester													
Produkt	Glas		Vikt	SP Borås			Pilkington Tyskland			Intygsnummer		Typ nr.	Anm
	Ytterbåge	Innerbåge	kg/m²	RW	Tåg C	Bil Ctr	RW	Tåg C	Bil Ctr	SP Borås	Tyskland		
SF-2010 Vrid	T4-16		30				35	33	29		35606	Std.	
SF-2010 Vrid	6-15-4-15-4		35				39	37	34		35615	20	
SF-2010 Vrid	8-12-4-16-4		40				40	39	35		35610	21	
SF-2010 Vrid	6-12-4-12-8,8		46				43	41	38		35609	22	
SF-2010 Vrid	8,8-10-4-12-8,8		52				45	43	41		35616	24	
SF-2010 Fast	8,8-10-4-12-8,8		52	44	42	38				5P03577-C1			
SF-2010 Fast	12,8-8-4-12-8,8		62	46	44	40				5P03577-C2			
SF-2010 Fast	12,8-22-8,8		52				50	49	46		36037		Dubbelruta
SF-2010 FD	T4-16		30	30	28	26				PX28735-1		Std.	
SF-2010 FD	T4-16 + ljudfyllning		30	34	32	29				PX28735-2		Std.	
SF-2010 FD	T4-16		30	34	33	29				PX28735-5		Std.	Helglasad
SF-2010 FD	6-15-4-15-4		35	37	35	30				8P07335-H			Helglasad
SF-2010 FD	6,8-14-4-15-4		35,8	38	36	31				8P07335-A			Helglasad
SF-2010 FD	6-12-4-12-8,8LP		45,8	42	40	36				8P07335-E			Helglasad
SF-2010 FD	8,8LP-10-4-12-8,8LP		51,6	43	41	37				8P07335-G			Helglasad
SF-2010 FD	6-15-4-15-4 + ljudfy		35,0	35	35	32				PX28735-3		20	Ljudfyllning
INTAKT 2+1	4	4- 16 -4	30	39	37	31	41	39	33	4P00592-9	35804	Std.	
INTAKT 2+1	6	4- 16 -4	35	41	39	35	44	42	37	4P00592-7	35810	1	
INTAKT 2+1	6	4- 16 -6	40	42	39	35	43	41	37	4P04344-2	35917	2	
INTAKT 2+1	6	4- 18 -8	45	44	41	36	44	42	39	4P04729-6	35915	3	
INTAKT 2+1	6,8*	4 -18 -8	45,5	46	43	38	46	44	40	4P04729-7	35955	4	
INTAKT 2+1	6,8*	8- 16 -8,8	57	46	45	41	48	47	42	3P03622-9	35799	5	
INTAKT 2+1	6,8	4- 16 -8,8	47	47	44	39	47	46	42	4P04729-16	35948	6	
INTAKT 2+1	6,8	4- 16 -12,8	57	48	46	43	48	47	44	4P04729-14	35951	7	
2+1 Mötesbåge	4	4- 16 -4	30	39	37	31	40	38	32	4P00592-14	35914	Std.	
2+1 med VL	4	4- 16 -4	30	37	36	32				6P10385-A		Std.	
2+1 med VL	6,8*	4- 18 -8	45	41	39	36				6P10385-B		4	
INTAKT 3-glas	T4-16		30	34	32	27				4P04344-1		Std.	
INTAKT 3-glas	6-15-4-15-4		35	37	35	31				6P10385-D		20	
INTAKT 3-glas	6-12-4-12-8,8		46	41	39	35				6P10385-E		22	
INTAKT 3-glas	8,8-10-4-12-8,8		52	43	41	38				5P0377-A5		24	
INTAKT Passiv	4	T4-16	40	39	37	31	39	38	33	4P00592-13	35916	Std.	
INTAKT Passiv	4	4-14-4-16-6	45				44	40	37		35958		
INTAKT Passiv	4	4-10-4-12-8,8	51				46	44	40		35957		
INTAKT 2+1 Ut FD	4	4-16-4	30	35	33	29				5P03309-5			Std fyllning
INTAKT 2+1 Ut FD	4	4-16-4	30	36	35	30				5P03309-1			Glas i bröstn
INTAKT 2+1 Ut FD	6	4-16-4	35	37	35	31				5P03309-3			Ljudfyllning
INTAKT 2+1 Ut FD	6	4-16-4	35	39	37	32				5P03309-2			Glas i bröstn
INTAKT 2+1 Ut FD	6	4-16-8	45	41	40	35				5P03309-4			Glas i bröstn
INTAKT 2+1 Ut FD	6,8	4-18-8	46	40	38	33				5P05738-5			Ljudfyllning
INTAKT 2+1 Ut FD	6,8	4-18-8	46	42	39	34				5P05738-1			Glas i bröstn
INTAKT 2+1 Ut FD	6,8	4-16-8,8	47	43	41	35				5P05738-6			Glas i bröstn
Lingbo 2+1	4	4- 9 -4	30	32	30	27				PX14150		Std.	
Lingbo 2+1	6	4- 8 -6,8	41	36	35	30				6P10385-H			Ljudlistning

* 6,4mm lam i testrapporten